

Field modifications, including cutting can alter product performance or tier ratings published. Please follow the below field modification guideline to maintain performance integrity to your Maximus™ HD handholes.

MODIFICATION GUIDELINES

- + Modifying Maximus™ HD handholes can be completed with standard tools. Be sure to follow safety guidelines set forth by your organization when using tools to modify products.
- + Holes and conduit entries can be cut into Maximus™ HD bodies anywhere within the acceptable flat areas on the body as shown in green in the below diagram.
- + Holes and modifications should be separated by at least one-half of the diameter hole or dimension of the cutout being created in the sidewall
EXAMPLE: If cutting two 3" diameter holes, they should be separated by 1.5" between the edge of each hole
- + When modifying Maximus™ HD, do not remove more than 25% of material from any sidewall or handhole.

ACCEPTABLE CUTTING AREAS

